

CASADECO

Flame Retardancy Certificate

Texdecor hereby declares that the wallcoverings listed below are in accordance with the procedures given in the standards EN15102:2007 & EN 13501-1+A1: 2009: Fire classification of construction products and building elements – Part 1: classification using data from reaction to fire tests.

Construction product: **Vinyl on Non-Woven described as "ENCYCLOPEDIA"**

Placed on the market by: **Texdecor**

**2 rue d'Hem
59780 Willems
France**

Application: **decorative wallpaper glued onto wall supports**

This product in relation to its reaction to fire behaviour is classified as:
Euroclass B-s2, d0

By means of this certificate, the supplier affirms that the product placed on the market shall bear euroclass marking indicating its conformity to all of the required conditions.

Date: 01.06.18

TEXDECOR
2, rue d'Hem
F 59780 WILLEMS
Tél. : + 33 3 20 61 75 41
Fax : + 33 3 20 61 75 66

Benoit JANSSENS

Quality Manager

Wallpaper & Wallcovering Department

Registered offices at: 2 rue d'Hem – 59780 Willems
Tel. (33) 3.20.61.78.37 – Fax (33) 3.20.61.75.64

www.texdecor.fr
email contact@texdecor.com